

Stormwater Management

410-887-3768  
FAX 410-887-4804

March 25, 2014

Arm Group Inc.  
9175 Guilford Road, Suite 310  
Columbia, MD 21046  
Attn: Kevin Schiefer

RE: SPARROWS POINT COKE OVEN CELL 2 & 5  
Stormwater Management Variance  
Patapsco Watershed  
**EPS Project I.D. M140050**  
**EPS Tracking Number for Cell 2: 07-14-1786**  
**EPS Tracking Number for Cell 5: 07-14-1787**

Dear Mr. Schiefer:

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations. This project is for the installation of wells and pipes by cut and cover. The existing cover conditions will be re-established once the pipes and wells are installed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Tony Okechukwu Ezirike, P.E. of my staff at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Thomas L. Vidmar, P.E., Deputy Director  
Department of Environmental Protection  
& Sustainability

TLV:jcm